Nathan Blanchard

From: Elgan Jones <elgan.jones@spab.org.uk>
Sent: 10 November 2026 12:23
To: Nathan Blanchard
Subject: St Rhedyw, Llanllyfni

Your reference: 2026-015351

Our reference: 223783

St Rhedyw, Llanllyfni

Dear Nathan,

Thank you for consulting the SPAB over the proposals to undertake repair to the grade II* listed church. Whilst we have not had an opportunity to visit the site, we have reviewed the documentation submitted online and would like to provide the following observations.

The proposals included within this application appear well considered and appropriate to address the deteriorated condition, inappropriate technical interventions and safeguard the character and historic building fabric. Our only minor observation is that the condition of the high level masonry embedded into the gable should be checked once safe access is available. We note a provisional sum to cover 'timber repairs' is included within the schedule.

Kind regards,

Elgan

Elgan Jones

Casework Officer

The Society for the Protection of Ancient Buildings

37 Spital Square, London E1 6DY

Support the SPAB, become a member | spab.org.uk

Facebook | Twitter | Instagram | YouTube

Charity no: 111 3753 Scottish charity no: SC 039244 Registered in Ireland 20158736 Company no: 5743962

